



DC Scholars PCS - Lead in Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
DC Scholars PCS	WS-097-001	Cooler	2	In hallway across from stage entrance	-	-	WF-112017-097001-01		FT-FY18-112017-097001	<1	<1
DC Scholars PCS	WS-097-002	Cooler	2	In hallway adjacent to room 203	-	-	WF-112017-097002-01		FT-FY18-112017-097002	<1	<1
DC Scholars PCS	WS-097-003	Cooler	2	In hallway across from room 210	-	-	WF-112017-097003-01		FT-FY18-112017-097003	<1	<1
DC Scholars PCS	WS-097-004	Cooler	2	In hallway across from room 212	-	-	WF-112017-097004-01		FT-FY18-112017-097004	<1	<1
DC Scholars PCS	WS-097-005	Cooler	2	In hallway adjacent to room 216	-	-	WF-112017-097005-01		FT-FY18-112017-097005	<1	<1
DC Scholars PCS	WS-097-006	Combo Faucet	1	In classroom 119	-	Left	WF-112017-097006-01		FT-FY18-112017-097006	1.5	<1
DC Scholars PCS	WS-097-007	Combo Fountain	1	In classroom 119	-	Right	WF-112017-097007-01		FT-FY18-112017-097007	<1	<1
DC Scholars PCS	WS-097-008	Combo Faucet	1	In classroom 117	-	Left	WF-112017-097008-01		FT-FY18-112017-097008	3.4	<1
DC Scholars PCS	WS-097-009	Combo Fountain	1	In classroom 117	-	Right	WF-112017-097009-01		FT-FY18-112017-097009	<1	<1
DC Scholars PCS	WS-097-010	Cooler	1	In hallway across from room 115	-	-	WF-112017-097010-01		FT-FY18-112017-097010	<1	<1
DC Scholars PCS	WS-097-011	Combo Faucet	1	In classroom 113	-	Left	WF-112017-097011-01		FT-FY18-112017-097011	1.0	<1
DC Scholars PCS	WS-097-012	Combo Fountain	1	In classroom 113	-	Right	WF-112017-097012-01	N/A	FT-FY18-112017-097012	N/A	
DC Scholars PCS	WS-097-013	Cooler	1	In hallway across from room 110	-	-	WF-112017-097013-01		FT-FY18-112017-097013	<1	<1
DC Scholars PCS	WS-097-014	Combo Faucet	1	In classroom 110	-	Left	WF-112017-097014-01		FT-FY18-112017-097014	<1	<1
DC Scholars PCS	WS-097-015	Combo Fountain	1	In classroom 110	-	Right	WF-112017-097015-01		FT-FY18-112017-097015	<1	<1
DC Scholars PCS	WS-097-016	Combo Faucet	1	In classroom 111	-	Left	WF-112017-097016-01		FT-FY18-112017-097016	<1	<1
DC Scholars PCS	WS-097-017	Combo Fountain	1	In classroom 111	-	Right	WF-112017-097017-01		FT-FY18-112017-097017	<1	<1
DC Scholars PCS	WS-097-018	Combo Faucet	1	In classroom 108	-	Left	WF-112017-097018-01		FT-FY18-112017-097018	1.8	<1
DC Scholars PCS	WS-097-019	Combo Fountain	1	In classroom 108	-	Right	WF-112017-097019-01		FT-FY18-112017-097019	1.6	<1
DC Scholars PCS	WS-097-020	Combo Faucet	1	In classroom 109	-	Left	WF-112017-097020-01		FT-FY18-112017-097020	1.8	<1
DC Scholars PCS	WS-097-021	Combo Fountain	1	In classroom 109	-	Right	WF-112017-097021-01	N/A	FT-FY18-112017-097021	N/A	
DC Scholars PCS	WS-097-022	Combo Faucet	1	In classroom 106	-	Left	WF-112017-097022-01		FT-FY18-112017-097022	1.6	<1
DC Scholars PCS	WS-097-023	Combo Fountain	1	In classroom 106	-	Right	WF-112017-097023-01		FT-FY18-112017-097023	<1	<1



DC Scholars PCS - Lead in Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
DC Scholars PCS	WS-097-024	Cooler	1	In hallway across from room 106	-	-	WF-112017-097024-01		FT-FY18-112017-097024	<1	<1
DC Scholars PCS	WS-097-025	Combo Faucet	1	In classroom 104	-	Left	WF-112017-097025-01		FT-FY18-112017-097025	1.7	<1
DC Scholars PCS	WS-097-026	Combo Fountain	1	In classroom 104	-	Right	WF-112017-097026-01		FT-FY18-112017-097026	<1	<1
DC Scholars PCS	WS-097-027	Break Room	1	In staff lounge 103	-	-	WF-112017-097027-01		FT-FY18-112017-097027	<1	<1
DC Scholars PCS	WS-097-028	Cooler	1	In hallway adjacent to room 101	-	-	WF-112017-097028-01		FT-FY18-112017-097028	<1	<1
DC Scholars PCS	WS-097-029	Health Suite	1	In nurse suite 101	-	-	WF-112017-097029-01		FT-FY18-112017-097029	<1	<1