



# DC Scholars PCS - Lead in Water Test Results



## FY21 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
DC Scholars PCS	WS-097-001	Cooler	2	In hallway across from stage entrance			WF-022021-097001-03	5/27/2021	FT-FY21-022021-097001-A	<1	FT-FY21-022021-097001-B	<1
DC Scholars PCS	WS-097-002	Cooler	2	In hallway adjacent to room 203			WF-022021-097002-03	N/A	FT-FY21-022021-097002-A	Non-Op	FT-FY21-022021-097002-B	Non-Op
DC Scholars PCS	WS-097-003	Cooler	2	In hallway across from room 210			WF-022021-097003-03	5/27/2021	FT-FY21-022021-097003-A	<1	FT-FY21-022021-097003-B	<1
DC Scholars PCS	WS-097-004	Cooler	2	In hallway across from room 212			WF-022021-097004-03	5/27/2021	FT-FY21-022021-097004-A	<1	FT-FY21-022021-097004-B	<1
DC Scholars PCS	WS-097-005	Cooler	2	In hallway adjacent to room 216			WF-022021-097005-03	5/27/2021	FT-FY21-022021-097005-A	<1	FT-FY21-022021-097005-B	<1
DC Scholars PCS	WS-097-006	Combo Faucet	1	In classroom 119		Left	WF-022021-097006-03	5/27/2021	FT-FY21-022021-097006-A	1.6	FT-FY21-022021-097006-B	<1
DC Scholars PCS	WS-097-007	Combo Fountain	1	In classroom 119		Right	WF-022021-097007-03	5/27/2021	FT-FY21-022021-097007-A	<1	FT-FY21-022021-097007-B	<1
DC Scholars PCS	WS-097-008	Combo Faucet	1	In classroom 117		Left	WF-022021-097008-03	5/27/2021	FT-FY21-022021-097008-A	1.6	FT-FY21-022021-097008-B	<1
DC Scholars PCS	WS-097-009	Combo Fountain	1	In classroom 117		Right	WF-022021-097009-03	5/27/2021	FT-FY21-022021-097009-A	<1	FT-FY21-022021-097009-B	<1
DC Scholars PCS	WS-097-010	Cooler	1	In hallway across from room 115			WF-022021-097010-03	5/27/2021	FT-FY21-022021-097010-A	<1	FT-FY21-022021-097010-B	<1
DC Scholars PCS	WS-097-011	Combo Faucet	1	In classroom 113		Left	WF-022021-097011-03	5/27/2021	FT-FY21-022021-097011-A	1.5	FT-FY21-022021-097011-B	<1
DC Scholars PCS	WS-097-012	Combo Fountain	1	In classroom 113		Right	WF-022021-097012-03	N/A	FT-FY21-022021-097012-A	Non-Op	FT-FY21-022021-097012-B	Non-Op
DC Scholars PCS	WS-097-013	Cooler	1	In hallway across from room 110			WF-022021-097013-03	5/27/2021	FT-FY21-022021-097013-A	2.8	FT-FY21-022021-097013-B	2.4
DC Scholars PCS	WS-097-014	Combo Faucet	1	In classroom 110		Left	WF-022021-097014-03	5/27/2021	FT-FY21-022021-097014-A	1.0	FT-FY21-022021-097014-B	<1
DC Scholars PCS	WS-097-015	Combo Fountain	1	In classroom 110		Right	WF-022021-097015-03	5/27/2021	FT-FY21-022021-097015-A	2.4	FT-FY21-022021-097015-B	<1
DC Scholars PCS	WS-097-016	Combo Faucet	1	In classroom 111		Left	WF-022021-097016-03	5/27/2021	FT-FY21-022021-097016-A	2.4	FT-FY21-022021-097016-B	<1
DC Scholars PCS	WS-097-017	Combo Fountain	1	In classroom 111		Right	WF-022021-097017-03	5/27/2021	FT-FY21-022021-097017-A	<1	FT-FY21-022021-097017-B	<1
DC Scholars PCS	WS-097-018	Combo Faucet	1	In classroom 108		Left	WF-022021-097018-03	5/27/2021	FT-FY21-022021-097018-A	2.3	FT-FY21-022021-097018-B	<1
DC Scholars PCS	WS-097-019	Combo Fountain	1	In classroom 108		Right	WF-022021-097019-03	5/27/2021	FT-FY21-022021-097019-A	<1	FT-FY21-022021-097019-B	<1
DC Scholars PCS	WS-097-020	Combo Faucet	1	In classroom 109		Left	WF-022021-097020-03	5/27/2021	FT-FY21-022021-097020-A	2.2	FT-FY21-022021-097020-B	<1
DC Scholars PCS	WS-097-021	Combo Fountain	1	In classroom 109		Right	WF-022021-097021-03	5/27/2021	FT-FY21-022021-097021-A	<1	FT-FY21-022021-097021-B	<1
DC Scholars PCS	WS-097-022	Combo Faucet	1	In classroom 106		Left	WF-022021-097022-03	5/27/2021	FT-FY21-022021-097022-A	2.6	FT-FY21-022021-097022-B	<1
DC Scholars PCS	WS-097-023	Combo Fountain	1	In classroom 106		Right	WF-022021-097023-03	5/27/2021	FT-FY21-022021-097023-A	4.5	FT-FY21-022021-097023-B	<1
DC Scholars PCS	WS-097-024	Cooler	1	In hallway across from room 106			WF-022021-097024-03	5/27/2021	FT-FY21-022021-097024-A	<1	FT-FY21-022021-097024-B	<1
DC Scholars PCS	WS-097-025	Combo Faucet	1	In classroom 104		Left	WF-022021-097025-03	5/27/2021	FT-FY21-022021-097025-A	1.0	FT-FY21-022021-097025-B	<1
DC Scholars PCS	WS-097-026	Combo Fountain	1	In classroom 104		Right	WF-022021-097026-03	5/27/2021	FT-FY21-022021-097026-A	<1	FT-FY21-022021-097026-B	<1
DC Scholars PCS	WS-097-027	Break Room	1	In staff lounge 103			WF-022021-097027-03	5/27/2021	FT-FY21-022021-097027-A	<1	FT-FY21-022021-097027-B	<1
DC Scholars PCS	WS-097-028	Cooler	1	In hallway adjacent to room 101			WF-022021-097028-03	5/27/2021	FT-FY21-022021-097028-A	<1	FT-FY21-022021-097028-B	<1
DC Scholars PCS	WS-097-029	Health Suite	1	In nurse suite 101			WF-022021-097029-03	5/27/2021	FT-FY21-022021-097029-A	<1	FT-FY21-022021-097029-B	<1